


Generation and Reservoirs Statistics

September 12, 2020



PUBLIC UTILITIES COMMISSION OF SRI LANKA

Daily Generation Mix in MWh



Total Generation 38,710 MWh

Note: Generation from other SPPs (Mini Hydro and Biomass) is not included

Cumulative Dispatch

Note: Generation from other SPPs (Mini Hydro, small scale Solar and Biomass) is not included

For Current Month


Category	Dispatch (GWh)	
CEB Hydro	145.8	30.61%
CEB Thermal Oil	39.9	8.37%
CEB Coal	197.1	41.37%
IPP Thermal	77.9	16.36%
SPP Wind	12.7	2.67%
SPP Solar	3.0	0.62%
Total	476.4	

For Current Year

Category	Dispatch (GWh)	
CEB Hydro	2,478.6	24.58%
CEB Thermal Oil	1,094.5	10.85%
CEB Coal	4,169.6	41.35%
IPP Thermal	2,041.5	20.24%
SPP Wind	228.9	2.27%
SPP Solar	71.3	0.71%
Total	10,084.3	

Thermal Plant Dispatch


September 12, 2020



Available Generation is estimated based on plant availability at 6.00am on

September 13, 2020


Thermal Plant Loading at the Night Peak



Note- Plant availability is recorded at 6.00 am on September 13, 2020

Major Hydro Plant Dispatch

September 12, 2020




Note- Available Generation is estimated based on plant availability at 6.00am on

#####

Major Hydro Plant Loading at Night Peak


September 12, 2020



Note- Plant availability is recorded at 6.00 am on September 13, 2020

Contribution to the Night Peak in MW

September 12, 2020



Night Peak*	2,146.5 MW
Day Peak	1,829.6 MW
Minimum Demand	1,239.8 MW

Notes:


*The above chart pattern and night peak figure is presented excluding the contribution of Moragahakanda, other minihydro and biomass power plants from June 8 2020 onwards

**Day peak and Minimum demand includes the contribution from Moragahakanda, wind and solar plants

* in addition to the night peak figure presented above, Moragahakanda plant, other MiniHydro and Biomass

Plants of installed capacity 216.00 MW has recorded total 126.00 MW at night peak


Reservoir Levels - as at 06.00 Hr on September 13, 2020




Total Reservoir Level(GWh) 764.2
% of Total capacity 63.4%

Comparison of Total Reservoir Storage Levels with Past Years


Data from June 2018 to March 2020 are not indicated in the graph



Variation of Major Hydro Reservoir Levels in the current year (GWh)



Variation of Demand during the current year



Notes: The night peak graph in the above chart is revised from June 8, 2020 to exclude the contribution from Mini hydro and biomass power plants


Day peak and minimum demand graphs includes the contribution from Moragahakanda power plant

All graphs include the contribution telemetered from solar and wind plants

Daily Load Curve of the Previous day

September 11, 2020


Not available



Coal Generation during the Previous day

September 11, 2020


Not available



CEB Oil Plant Generation during the Previous day

September 11, 2020


Not available



IPP Oil Plant Generation during the Previous day

September 11, 2020


Not available



Major Hydro Generation during the Previous day

September 11, 2020


Not available



Wind Generation during the Previous day

September 11, 2020


Not available



Solar Generation during the Previous day

September 11, 2020

Not available



Plant	Installed Capacity	Plant Availability	Night peak Load	Plant Dispatch
	(MW)	(MW)	(MW)	(GWh)
Wimalasurendra	50.00	50.00	30.00	293.00
Old Laxapana	53.80	37.00	34.30	823.00
Canyon	60.00	60.00	30.00	725.00
New Laxapana	116.00	106.00	107.00	2,433.00
Polpitiya	75.00	90.00	85.40	1,834.00
Kotmale	201.00	201.00	157.00	2,100.00
Victoria	210.00	234.00	212.00	2,671.00
Randenigala	122.00	45.00	46.00	162.00
Rantambe	49.00	50.00	40.00	67.00
Ukuwela	37.00	20.00	21.00	506.00
Bowatenna	40.00	40.00	39.00	151.00
Upper Kotmale	150.00	75.00	76.00	1,804.00
Nilambe	3.20	3.20	3.20	23.00
Samanalawewa	120.00	60.00	61.00	460.00
Kukule	75.00	75.00	76.70	1,261.00
Inginiyagala	11.25	11.25	-	-
Udawalawe	6.00	4.00	-	-
Puttalam Coal I	275.00	270.00	269.00	6,495.00
Puttalam Coal II	275.00	270.00	270.00	6,478.00
Puttalam Coal III	275.00	270.00	270.00	6,506.00
KPS Small GTs	65.20	35.00	-	-
KPS GT 7	113.00	-	-	-
KCCP	161.00	-	-	-
Sapugaskanda A	69.60	54.00	52.00	703.00
Sapugaskanda B	69.60	63.00	-	49.00
Uthura Janani	26.01	23.00	22.00	225.00
Barge CEB	60.00	60.00	60.00	939.00
CEB-Thulhiriya	10.00	8.00	10.00	4.00
CEB-Kolonnawa	20.00	16.00	10.00	4.00
CEB-Mathugama	20.00	16.00	16.00	7.00
ACE Matara	20.00	24.00	24.00	41.00
Asia Power	50.80	38.00	-	-
AES - Kelanitissa	163.00	163.00	-	-
Westcoast	270.00	270.00	-	-
ACE Embilipitiya	100.00	86.00	78.00	301.00
Vpower-Pallekele	24.00	24.00	19.00	15.00
Vpower-Galle	10.00	10.00	10.00	7.00
Vpower-Hamba.	24.00	-	-	-
Vpower-Horana	24.00	-	-	-
Altaaqa-Mahiya.	10.00	-	-	-
Altaaqa-Polon.	8.00	-	-	-
Solar	58.00		-	210.00
Wind	128.00		16.00	1,413.00
MH and BM	394.00		126.00	Not available
Total without NCRE	3,522.46	2,861.45		

Night peak load of MH and BM only include loading of Minihydro plants of total capacity MW 216

Installed capacity of Solar, wind, Mini-hydro and Biomass plants are as of end of December 2019

Plant availability is the availability recorded at 6 am on

September 13, 2020

Thermal Plant Fuel types

Power Station	Primary Fuel
CEB Thermal	
Sapugaskanda 1	Heavy Fuel
Sapugaskanda 2	Heavy Fuel
Kelanitissa Small Gas Turbines	Auto Diesel
GT 7 - Kelanitissa	Auto Diesel
Kelanitissa CCY	Naptha & Diesel
Lakvijaya 1	Coal
Lakvijaya 2	Coal
Lakvijaya 3	Coal
Uthuru Janani	Heavy Fuel
Barge CEB	Furnace Oil

Power Station	Primary Fuel
Private Thermal	
Asia Power	Heavy Fuel
Sojitz -	Auto Diesel
West Coast	Low Sulphur Furnace oil
ACE Embilipitiya	Furnace Oil

Major Incidents during the day

Nil