
Generation and Reservoirs Statistics

May 1, 2021



PUBLIC UTILITIES COMMISSION OF SRI LANKA

Daily Generation Mix in MWh





Cumulative Dispatch

Note: Generation from other SPPs (Mini Hydro, small scale Solar and Biomass) is not included

Category	Dispatch (GWh)		
CEB Hydro	9.1	24.54%	
CEB Thermal Oil	4.9	13.22%	
CEB Coal	19.6	52.81%	
IPP Thermal	3.1	8.27%	
SPP Wind	0.1	0.27%	
SPP Solar	0.3	0.75%	
Total	37.1		

For Current Month


For Current Year

Category	Dispatch (GWh)	
CEB Hydro	1,022.9	20.47%
CEB Thermal Oil	613.6	12.28%
CEB Coal	2,284.1	45.72%
IPP Thermal	1,000.0	20.02%
SPP Wind	34.2	0.68%
SPP Solar	31.2	0.62%
Total	4,996.4	


Thermal Plant Dispatch

May 1, 2021

ACE Embilipitiya, ACE Matara, Asia Power, V Power Pallekale, Vpower Galle, V Power Horana, Vpower Hambantota and Altaqa Mahiyanganaya are not available due to expiration of PPAs




Available Generation is estimated based on plant availability at 6.00am on May 2, 2021




Tharmal Plant Loading at the Night Peak

Note- Plant avilability is recorded at 6.00 am or May 2, 2021

Major Hydro Plant Dispatch



Note- Available Generation is estimated based on plant availability at 6.00am on May 2, 2021




Major Hydro Plant Loading at Night Peak

May 1, 2021

Note- Plant avilability is recorded at 6.00 am or May 2, 2021



May 1, 2021




Night Peak*	2,131.2	MW
Day Peak	1,609.8	MW
Minimum Demand	1,379.5	MW

Notes:

*The above chart pattern and night peak figure is presented excluding the contribution of Moragahakanda, other minihydro and biomass power plants


**Day peak and Minimum demand includes the contribution from Moragahakanda, wind and solar plants

* in addition to the night peak figure presented above, Moragahakanda plant, other MiniHydro and Biomass
Plants of installed capacity
199.00
MW has recorded total
106.60
MW at night peak



Reservoir Levels - as at 06.00 Hr on May 2, 2021


Total Reservoir Level(GWh)742.9% of Total capacity61.7%




Comparison of Total Reservoir Storage Levels with Past Years

Data for 2018 and 2019 are only available for part of year.

Variation of Major Hydro Reservoir Levels in the current year (GWh)





Variation of Demand during the current year


Notes:

The night peak is excluding the contribution from Minihydro and biomass power plants Day peak and minimum demand graphs includes the contribution from Moragahakanda power plant All graphs include the contribution from telemetered solar and wind plants


Daily Load Curve of the Previous day

April 30, 2021


Solar and wind data is based on Telemetered Power Stations only









CEB Oil Plant Generation during the Previous day April 30, 2021








Major Hydro Generation during the Previous day April 30, 2021




Wind Generation during the Previous day



Based on Telemetered Power Stations only

Solar Generation during the Previous day

April 30, 2021



Based on Telemetered Power Stations only

Summary of Major Plant performance

Plant	Installed Capacity		Night peak Load	Plant Dispatch
	(MW)	(MW)	(MW)	(GWh)
Wimalasurendra	50.00	50.00	10.00	243.00
Old Laxapana	53.80	54.00	51.30	660.00
Canyon	60.00	60.00	30.00	512.00
New Laxapana	116.00	100.00	90.00	1,592.00
Polpitiya	75.00	90.00	86.20	1,151.00
Kotmale	201.00	134.00	-	-
Victoria	210.00	231.00	159.00	1,253.00
Randenigala	122.00	104.00	85.00	762.00
Rantambe	49.00	50.00	40.00	360.00
Ukuwela	37.00	36.00	37.00	204.00
Bowatenna	40.00	38.00	11.00	19.00
Upper Kotmale	150.00	150.00	40.00	69.00
Nilambe	3.20	3.20	1.60	30.00
Samanalawewa	120.00	120.00	118.00	1,624.00
Kukule	75.00	75.00	52.00	418.00
Inginiyagala	11.25	11.25	6.40	149.00
Udawalawe	6.00	4.00	2.00	59.00
Puttalam Coal I	275.00	270.00	272.00	6,525.00
Puttalam Coal II	275.00	270.00	270.00	6,490.00
Puttalam Coal III	275.00	270.00	275.00	6,598.00
KPS Small GTs	65.20	48.00	-	-
KPS GT 7	113.00	115.00	-	-
КССР	161.00	100.00	149.00	769.00
Sapugaskanda A	69.60	64.00	50.00	1,230.00
Sapugaskanda B	69.60	63.00	62.00	1,414.00
Uthura Janani	26.01	23.00	23.20	303.00
Barge CEB	60.00	60.00	59.00	1,193.00
CEB-Thulhiriya	10.00	6.40	-	-
CEB-Kolonnawa	20.00	12.80	-	-
CEB-Mathugama	20.00	14.20	-	-
ACE Matara	20.00	-	-	-
Asia Power	50.80	-	-	-
AES - Kelanitissa	163.00	163.00	-	-
Westcoast	270.00	125.00	131.00	3,066.00
ACE Embilipitiya	100.00	-	-	-
Vpower-Pallekele	24.00	-	-	-
Vpower-Galle	10.00	-	-	-
Vpower-Hamba.	24.00	-	-	-
Vpower-Horana	24.00	-	-	-
Altaaqa-Mahiya.	10.00	-	-	-
Altaaqa-Polon.	24.00	24.00	-	-
Solar	58.00		-	279.00
Wind	128.00		20.10	162.00
MH and BM	394.00			Not available
Total without NCRE	3,538.46	2,938.85	1	

Night peak load of MH and BM only include loading of Minihydro plants of total capacity MW 199Installed capacity of Solar, wind, Mini-hydro and Biomass plants are as of end of December 2019Plant availability is the availability recorded at 6 am onMay 2, 2021

Thermal Plant Fuel types

Power Station	Primary Fuel
CEB Thermal	
Sapugaskanda 1	Heavy Fuel
Sapugaskanda 2	Heavy Fuel
Kelanitissa Small Gas	Auto Diesel
Turbines	Auto Diesei
GT 7 - Kelanitissa	Auto Diesel
Kelanitissa CCY	Naptha & Diesel
Lakvijaya 1	Coal
Lakvijaya 2	Coal
Lakvijaya 3	Coal
Uthuru Janani	Heavy Fuel
Barge CEB	Furnace Oil

Power Station	Primary Fuel
Private Thermal	
Asia Power	Heavy Fuel
Sojitz -	Auto Diesel
West Coast	Low Sulphur
West Coast	Furnace oil
ACE Embilipitiya	Furnace Oil

May 2, 2021

Major Incidents during the day -as reported by CEB morning of

1) Ukuwela 132/33kV T/F-01 tripped twice at 11:42 hrs & 12:05 hrs, respectively due to trip coil faulty. Ukuwela T/F 01 normalized at 12:00 hrs & 12:26 hrs, respectively.

2) N'Anura-Trinco cct 02 tripped and A/R from both ends at 12:15hrs due to operation of distance protection.

3) N'Laxapana-Balangoda cct 02 tripped from N'Laxapana end and tripped and A/R from Balangoda end at 15:26hrs due to operation of distance protection. N'Laxapana-Balangoda cct 02 normalized at 16:21hrs.

4) Sapugaskanda GSS 132/33kV T/F-01 tripped at 16:39 hrs due to operation of OLTC surge relay. T/F-01 is yet to be normalized.