


# **Generation and Reservoirs Statistics**

**June 13, 2021**



**PUBLIC UTILITIES COMMISSION OF SRI LANKA**

## Daily Generation Mix in MWh



**Total Generation 31,380 MWh**

Note: Minihydro and Biomass and waste heat (except 10 MW WH plant at Kerawalapitiya) power plant energy is not included

## Cumulative Dispatch

Note: Minihydro and Biomass and waste heat (except 10 MW WH plant at Kerawalapitiya) power plant energy is not included

### For Current Month


Category	Dispatch (GWh)	Percentage
CEB Hydro	296.0	64.20%
CEB Thermal Oil	1.3	0.27%
CEB Coal	120.5	26.13%
IPP Thermal	3.8	0.82%
SPP Wind	10.7	2.33%
CEB Wind	22.5	4.88%
SPP Solar	3.8	0.83%
SPP Waste Heat	2.5	0.54%
<b>Total</b>	<b>461.0</b>	

### For Current Year

Category	Dispatch (GWh)	Percentage
CEB Hydro	1,791.0	27.19%
CEB Thermal Oil	691.4	10.50%
CEB Coal	2,890.9	43.89%
IPP Thermal	1,035.7	15.72%
SPP Wind	61.6	0.94%
CEB Wind	69.2	1.05%
SPP Solar	42.6	0.65%
SPP Waste Heat	4.4	0.07%
<b>Total</b>	<b>6,586.6</b>	

# CEB owned Thermal Plant Dispatch


June 13, 2021



Available Generation is estimated based on plant availability at 6.00am on

June 14, 2021

# CEB owned Thermal Plant Loading at the Night Peak




Note- Plant availability is recorded at 6.00 am on

June 14, 2021

## IPP owned Thermal Plant Dispatch

June 13, 2021


ACE Embilipitiya, ACE Matara, Asia Power, V Power Pallekale, Vpower Galle, V Power Horana, Vpower Hambantota and Altaqa Mahiyangaya are not available due to expiration of PPAs



Available Generation is estimated based on plant availability at 6.00am on

June 14, 2021

## IPP owned Thermal Plant Loading at the Night Peak




Note- Plant availability is recorded at 6.00 am on

June 14, 2021

## Major Hydro Plant Dispatch

June 13, 2021




Note- Available Generation is estimated based on plant availability at 6.00am on

June 14, 2021

## Major Hydro Plant Loading at Night Peak

June 13, 2021




Note- Plant availability is recorded at 6.00 am on

June 14, 2021

## Contribution to the Night Peak in MW

June 13, 2021




Night Peak*	1,848.9 MW
Day Peak	1,358.9 MW
Minimum Demand	1,140.0 MW

Notes: \*The above chart pattern and night peak figure is presented excluding the contribution of Moragahakanda, other minihydro and biomass power plants

\*\*Day peak and Minimum demand includes the contribution from Moragahakanda, wind and solar plants


\* in addition to the night peak figure presented above, Kerawalapitiya waste heat plant, other MiniHydro and Biomass Plants of installed capacity 203.00 MW has recorded total 138.10 MW at night peak

## Reservoir Levels - as at 06.00 Hr on June 14, 2021




Total Reservoir Level(GWh)	1105.8
% of Total capacity	91.8%

### Comparison of Total Reservoir Storage Levels with Past Years




Data for 2018 and 2019 are only available for part of year.

### Variation of Major Hydro Reservoir Levels in the current year (GWh)



## Variation of Demand during the current year



### Notes:

The night peak is excluding the contribution from Minihydro and biomass power plants


Day peak and minimum demand graphs includes the contribution from Moragahakanda power plant

All graphs include the contribution from telemetered solar and wind plants

## Daily Load Curve of the Previous day

June 12, 2021


Solar and wind data is based on Telemetered Power Stations only






**Coal Generation during the Previous day**

**June 12, 2021**




**CEB Oil Plant Generation during the Previous day**

**June 12, 2021**




**IPP Oil Plant Generation during the Previous day**

**June 12, 2021**



**Major Hydro Generation during the Previous day**


**June 12, 2021**



### Wind Generation during the Previous day

June 12, 2021


Based on Telemetered Power Stations only



### Solar Generation during the Previous day

June 12, 2021

Based on Telemetered Power Stations only



Summary of Major Plant performance

Plant	Installed Capacity (MW)	Plant Availability (MW)	Night peak Load (MW)	Plant Dispatch (GWh)
Wimalasurendra	50.00	50.00	50.00	550.00
Old Laxapana	53.80	54.00	51.70	1,234.00
Canyon	60.00	60.00	30.00	730.00
New Laxapana	116.00	100.00	99.00	2,387.00
Polpitiya	75.00	90.00	89.80	2,059.00
Kotmale	201.00	201.00	125.00	1,530.00
Victoria	210.00	240.00	241.00	3,736.00
Randenigala	122.00	112.00	113.00	1,151.00
Rantambe	49.00	81.00	40.00	450.00
Ukuwela	37.00	36.00	37.00	735.00
Bowatenna	40.00	38.00	39.00	142.00
Upper Kotmale	150.00	150.00	150.00	1,694.00
Nilambe	3.20	3.20	1.60	51.00
Samanalawewa	120.00	120.00	120.00	1,083.00
Kukule	75.00	75.00	77.50	1,861.00
Inginiyagala	11.25	11.25	5.60	128.00
Udawalawe	6.00	4.00	2.00	58.00
Puttalam Coal I	275.00	270.00	265.00	4,025.00
Puttalam Coal II	275.00	270.00	231.00	3,949.00
Puttalam Coal III	275.00	-	-	-
KPS Small GTs	65.20	48.00	-	-
KPS GT 7	113.00	115.00	-	-
KCCP	161.00	-	-	-
Sapugaskanda A	69.60	68.00	-	-
Sapugaskanda B	69.60	36.00	-	-
Uthura Janani	26.01	24.00	-	-
Barge CEB	60.00	60.00	-	-
CEB-Thulhiriya	10.00	7.20	-	-
CEB-Kolonnawa	20.00	12.80	-	-
CEB-Mathugama	20.00	10.20	-	-
ACE Matara	20.00	-	-	-
Asia Power	50.80	-	-	-
AES - Kelanitissa	163.00	163.00	-	-
Westcoast	270.00	270.00	-	-
ACE Embilipitiya	100.00	-	-	-
Vpower-Pallekele	24.00	-	-	-
Vpower-Galle	10.00	-	-	-
Vpower-Hamba.	24.00	-	-	-
Vpower-Horana	24.00	-	-	-
Altaaqa-Mahiya.	10.00	-	-	-
Vpower-Valach.	24.00	24.00	-	-
Solar	58.00		-	291.00
Wind	128.00		82.20	3,330.00
MH and BM	394.00		138.10	Not available
Total without NCRE	3,538.46	2,803.65		

Night peak load of MH and BM only include loading of Minihydro plants of total capacity MW 203

Installed capacity of Solar, wind, Mini-hydro and Biomass plants are as of end of December 2019

Plant availability is the availability recorded at 6 am on

June 14, 2021

**Thermal Plant Fuel types**

<b>Power Station</b>	<b>Primary Fuel</b>
<b>CEB Thermal</b>	
<b>Sapugaskanda 1</b>	Heavy Fuel
<b>Sapugaskanda 2</b>	Heavy Fuel
<b>Kelanitissa Small Gas Turbines</b>	Auto Diesel
<b>GT 7 - Kelanitissa</b>	Auto Diesel
<b>Kelanitissa CCY</b>	Naptha & Diesel
<b>Lakvijaya 1</b>	Coal
<b>Lakvijaya 2</b>	Coal
<b>Lakvijaya 3</b>	Coal
<b>Uthuru Janani</b>	Heavy Fuel
<b>Barge CEB</b>	Furnace Oil

<b>Power Station</b>	<b>Primary Fuel</b>
<b>Private Thermal</b>	
<b>Asia Power</b>	Heavy Fuel
<b>Sojitz -</b>	Auto Diesel
<b>West Coast</b>	Low Sulphur Furnace oil
<b>ACE Embilipitiya</b>	Furnace Oil

**Major Incidents during the day -as reported by CEB morning of**

**June 14, 2021**

- 1) Laxapana pond spilling stopped at 09:45hrs and again started spilling at 19:18 hrs. Laxapana pond spilling continues to the present hour.
- 2) Norton pond spilling started at 12:20 hrs and spilling continues to the present hour.
- 3) Canyon pond spilling stopped at 05:49 hrs and again started spilling at 20:24 hrs. Canyon pond spilling continues to the present hour.
- 4) Kolonnawa 132/33kV T/F-05 tripped at 15:10 hrs from both ends due to operation of differential protection and T/F normalized at 16:45 hr
- 5) Upper Kothmale spilling started at 02:44 hrs on 14.06.2021.
- 6) Kukule spilling started at 04:00 hrs on 14.06.2021.