
# **Generation and Reservoirs Statistics**

August 23, 2021



PUBLIC UTILITIES COMMISSION OF SRI LANKA

#### **Daily Generation Mix in MWh**



#### **Total Generation**

38,280 MWh

Note: Minihydro and Biomass and waste heat (except 10 MW WH plant at Kerawalapitiya) power plant energy is not included

#### **Cumulative Dispatch**


Note: Minihydro and Biomass and waste heat (except 10 MW WH plant at Kerawalapitiya) power plant energy is not included

#### **For Current Month**


Category	Dispatch (GWh)	
CEB Hydro	365.6	38.69%
CEB Thermal Oil	58.7	6.22%
CEB Coal	433.8	45.91%
IPP Thermal	20.9	2.22%
SPP Wind	17.8	1.89%
CEB Wind	36.2	3.83%
SPP Solar	6.2	0.66%
SPP Waste Heat	5.6	0.59%
Total	944.8	

#### **For Current Year**

Category	Dispatch (GWh)	
CEB Hydro	3,101.2	32.77%
CEB Thermal Oil	888.5	9.39%
CEB Coal	3,902.1	41.23%
IPP Thermal	1,180.2	12.47%
SPP Wind	122.5	1.29%
CEB Wind	185.7	1.96%
SPP Solar	63.0	0.67%
SPP Waste Heat	20.4	0.22%
Total	9,463.4	



#### **CEB owned Tharmal Plant Loading at the Night Peak**




Note- Plant avilability is recorded at 6.00 am on August 24, 2021


#### **IPP owned Thermal Plant Dispatch**


#### August 23, 2021

ACE Embilipitiya, ACE Matara, Asia Power, V Power Pallekale, Vpower Galle, V Power Horana, Vpower Hambantota and Altaqa Mahiyanganaya are not available due to expiration of PPAs




#### IPP owned Tharmal Plant Loading at the Night Peak






**Major Hydro Plant Dispatch** 








## Major Hydro Plant Loading at Night Peak

August 23, 2021

#### Summary of Major Plant performance

Plant	Installed Capacity	Plant Availability	Night peak Load	Plant Dispatch
	(MW)	(MW)	(MW)	(GWh)
Wimalasurendra	50.00	50.00	50.00	558.00
Old Laxapana	53.80	54.00	53.50	1,282.00
Canyon	60.00	-	-	-
New Laxapana	116.00	100.00	100.00	2,400.00
Polpitiya	75.00	90.00	88.80	1,970.00
Kotmale	201.00	201.00	170.00	1,020.00
Victoria	210.00	234.00	231.00	3,785.00
Randenigala	122.00	112.00	110.00	301.00
Rantambe	49.00	50.00	25.00	122.00
Ukuwela	37.00	18.00	36.00	692.00
Bowatenna	40.00	38.00	39.00	472.00
Upper Kotmale	150.00	150.00	150.00	1,297.00
Nilambe	3.20	3.20	3.20	42.00
Samanalawewa	120.00	120.00	119.00	687.00
Kukule	75.00	75.00	76.20	572.00
Inginiyagala	11.25	11.25	-	-
Udawalawe	6.00	4.00	-	-
Puttalam Coal I	275.00	270.00	269.00	6,254.00
Puttalam Coal II	275.00	270.00	268.00	6,276.00
Puttalam Coal III	275.00	270.00	270.00	6,287.00
KPS Small GTs	65.20	36.00	-	-
KPS GT 7	113.00	115.00	-	-
КССР	161.00	150.00	-	-
Sapugaskanda A	69.60	48.00	-	-
Sapugaskanda B	69.60	54.00	53.00	709.00
Uthura Janani	26.01	16.00	15.50	65.00
Barge CEB	60.00	60.00	60.00	490.00
CEB-Thulhiriya	10.00	8.00	-	-
CEB-Kolonnawa	20.00	14.40	-	-
CEB-Mathugama	20.00	15.80	-	-
AES - Kelanitissa	163.00	163.00	-	-
Westcoast	270.00	270.00	-	-
Vpower-Valach.	24.00	24.00	24.00	14.00
Solar	58.00		-	310.00
Wind	128.00		89.10	2,411.00
MH and BM	394.00		89.90	Not available
Total without NCRE	3,538.46	3,094.65	•	•

Night peak load of MH and BM only include loading of Minihydro plants of total capacity MW199Installed capacity of Solar, wind, Mini-hydro and Biomass plants are as of end of December 2019Plant availability is the availability recorded at 6 am onAugust 24, 2021




Night Peak*	2,303.1	MW
Day Peak	1,765.4	MW
Minimum Demand	1,127.6	MW

Notes:

\*The above chart pattern and night peak figure is presented excluding the contribution of Moragahakanda, other minihydro and biomass power plants


\*\*Day peak and Minimum demand includes the contribution from Moragahakanda, wind and solar plants

\* in addition to the night peak figure presented above, Kerawalapitiya waste heat plant, other MiniHydro and Biomass Plants of installed capacity 199.00 MW has recorded total 89.90 MW at night peak



#### **Reservoir Levels** as at 06.00 Hr on August 24, 2021


Total Reservoir Level(GWh) 935.7 % of Total capacity 77.6%




#### **Comparison of Total Reservoir Storage Levels with Past Years**

Data for 2018 and 2019 are only available for part of year.

### Variation of Major Hydro Reservoir Levels in the current year (GWh)





#### Variation of Demand during the current year


#### Notes:

The night peak is excluding the contribution from Minihydro and biomass power plants Day peak and minimum demand graphs includes the contribution from Moragahakanda power plant All graphs include the contribution from telemetered solar and wind plants


#### Daily Load Curve of the Previous day

### August 22, 2021

Solar and wind data is based on Telemetered Power Stations only









### **CEB Oil Plant Generation during the Previous day**

August 22, 2021




### August 22, 2021



#### Major Hydro Generation during the Previous day

August 22, 2021


August 22, 2021



### IPP Oil Plant Generation during the Previous day


### Wind Generation during the Previous day

Based on Telemetered Power Stations only



#### Solar Generation during the Previous day

August 22, 2021



Based on Telemetered Power Stations only

**Thermal Plant Fuel types** 

Power Station	Primary Fuel	
CEB Thermal		
Sapugaskanda 1	Heavy Fuel	
Sapugaskanda 2	Heavy Fuel	
Kelanitissa Small Gas	Auto Diesel	
Turbines	Auto Diesei	
GT 7 - Kelanitissa	Auto Diesel	
Kelanitissa CCY	Naptha & Diesel	
Lakvijaya 1	Coal	
Lakvijaya 2	Coal	
Lakvijaya 3	Coal	
Uthuru Janani	Heavy Fuel	
Barge CEB	Furnace Oil	

Power Station	Primary Fuel
Private Thermal	
Sojitz -	Auto Diesel
West Coast	Low Sulphur
	Furnace oil

Major Incidents during the day -as reported by CEB morning of Nil

August 24, 2021