


Generation and Reservoirs Statistics

February 25, 2022



PUBLIC UTILITIES COMMISSION OF SRI LANKA

Daily Generation Mix in MWh



Total Generation 43,189 MWh

Note: Above data is excluding contribution from Roof Top Solar, 1MW Solar and certain Mini Hydro plants

Cumulative Dispatch

Note: Following data is Excluding contribution from Roof Top Solar, 1MW solar and Mini Hydro plants

For Current Month


Category	Dispatch (GWh)	Percentage
CEB Hydro	247.8	22.56%
CEB Thermal Oil	154.9	14.10%
CEB Coal	478.0	43.53%
IPP Thermal	165.3	15.05%
SPP Wind	10.9	0.99%
CEB Wind	13.7	1.24%
SPP Solar	6.3	0.58%
SPP Solid Waste	2.2	0.20%
Mini Hydro	19.1	1.74%
Total	1,098.1	

For Current Year

Category	Dispatch (GWh)	Percentage
CEB Hydro	655.1	26.87%
CEB Thermal Oil	399.0	16.36%
CEB Coal	885.3	36.31%
IPP Thermal	369.4	15.15%
SPP Wind	26.2	1.07%
CEB Wind	31.8	1.30%
SPP Solar	14.3	0.58%
SPP Solid Waste	10.3	0.42%
Mini Hydro	47.3	1.94%
Total	2,438.3	

CEB owned Thermal Plant Dispatch


February 25, 2022



Available Generation is estimated based on plant availability at 6.00am on

February 26, 2022

CEB owned Thermal Plant Loading at the Night Peak




Note- Plant availability is recorded at 6.00 am on

February 26, 2022

IPP owned Thermal Plant Dispatch

February 25, 2022


ACE Embilipitiya, ACE Matara, Asia Power, V Power Pallekale, Vpower Galle, V Power Horana, Vpower Hambantota, Vpower Valachchena and Altaqa Mahiyanganaya are not available due to expiration of PPAs



Available Generation is estimated based on plant availability at 6.00am on

February 26, 2022

IPP owned Thermal Plant Loading at the Night Peak




Note- Plant availability is recorded at 6.00 am on

February 26, 2022

Major Hydro Plant Dispatch

February 25, 2022




Available Generation is estimated based on plant availability at 6.00am on
Broadlands power plant is operating in the Commissioning Stage

February 26, 2022

Major Hydro Plant Loading at Night Peak

February 25, 2022



Note- Plant availability is recorded at 6.00 am on
Broadlands power plant is operating in the Commissioning Stage

February 26, 2022

Summary of Major Plant performance


Plant	Installed Capacity	Plant Availability	Night peak Load	Plant Dispatch
	(MW)	(MW)	(MW)	(MWh)
Wimalasurendra	50	50	0	72
Old Laxapana	54	54	5	157
Canyon	60	0	0	0
New Laxapana	100	100	80	1,245
Polpitiya	90	90	39	601
Broadlands	35	0	4	9
Kotmale	201	201	45	1,110
Victoria	225	225	69	690
Randenigala	114	114	53	953
Rantambe	50	50	36	468
Ukuwela	37	36	36	464
Bowatenna	40	40	25	35
Upper Kotmale	150	150	0	30
Nilambe	3	2	0	1
Samanalawewa	120	120	101	1,211
Kukule	75	75	26	155
Inginiyagala	11	5	0	0
Udawalawe	6	2	0	73
Puttalam Coal I	270	270	270	6,490
Puttalam Coal II	270	270	272	6,477
Puttalam Coal III	270	270	272	6,511
KPS Small GTs	64	0	0	0
KPS GT 7	115	0	0	0
KCCP	161	0	0	0
Sapugaskanda A	70	64	48	1,075
Sapugaskanda B	70	63	63	1,451
Uthura Janani	26	23	24	482
Barge CEB	60	0	0	714
CEB-Thulhiriya	10	0	0	0
CEB-Kolonnawa	20	0	0	0
CEB-Mathugama	20	0	1	4
Sojitz Kelanitissa	163	130	128	3,006
West Coast	270	270	285	6,687
Total	3,280	2,674	2,013	43,189

Plant availability is the availability recorded at 6 am on

February 26, 2022

Contribution to the Night Peak in MW


February 25, 2022



Night Peak*	1,996.6 MW
Day Peak	1,908.0 MW
Minimum Demand	1,464.8 MW


Above figures are excluding contribution from Roof Top Solar, 1MW solar, certain Wind plants and Mini Hydro plants

Reservoir Levels - as at 06.00 Hr on February 26, 2022




Total Reservoir Level	495.4 GWh
% of Total capacity	39.9%

Comparison of Total Reservoir Storage Levels with Past Years




Data for 2018 and 2019 are only available for part of year.

Variation of Major Hydro Reservoir Levels in the current year (GWh)



Variation of Demand during the current year




The above figures are excluding contribution from Roof Top Solar, 1MW solar, certain Wind plants and Mini Hydro plants

Daily Load Curve of the Previous day


February 24, 2022

Solar and wind data is based on Telemetered Power Stations only




Coal Generation during the Previous day

February 24, 2022




CEB Oil Plant Generation during the Previous day

February 24, 2022




IPP Oil Plant Generation during the Previous day

February 24, 2022



Major Hydro Generation during the Previous day


February 24, 2022



Wind Generation during the Previous day

February 24, 2022


Based on Telemetered Power Stations only




Solar Generation during the Previous day

February 24, 2022

Based on Telemetered Power Stations only



Cumulative Dispatch Comparison with Last Year



Thermal Plant Fuel types

Power Station	Primary Fuel
CEB Thermal	
Sapugaskanda 1	Heavy Fuel
Sapugaskanda 2	Heavy Fuel
Kelanitissa Small Gas Turbines	Auto Diesel
GT 7 - Kelanitissa	Auto Diesel
Kelanitissa CCY	Naphtha & Diesel
Lakvijaya 1	Coal
Lakvijaya 2	Coal
Lakvijaya 3	Coal
Uthuru Janani	Heavy Fuel
Barge CEB	Heavy Fuel

Power Station	Primary Fuel
Private Thermal	
Sojitz - Kelanitissa	Auto Diesel
West Coast	Auto Diesel

Major Incidents during the day -as reported by CEB morning of

February 26, 2022

- 1) Rotational manual load shedding carried out from 08:30 hrs to 22:30 hrs .