


Generation and Reservoirs Statistics

April 25, 2022



PUBLIC UTILITIES COMMISSION OF SRI LANKA

Daily Generation Mix in MWh



Total Generation **42,959 MWh**

Note: Above data is excluding contribution from Roof Top Solar, 1MW Solar and certain Mini Hydro plants

Cumulative Dispatch

Note: Following data is Excluding contribution from Roof Top Solar, 1MW solar and Mini Hydro plants

For Current Month


Category	Dispatch (GWh)	Percentage
CEB Hydro	178.99	19.41%
CEB Thermal Oil	106.30	11.53%
CEB Coal	474.72	51.49%
IPP Thermal	104.21	11.30%
SPP Wind	6.99	0.76%
CEB Wind	8.96	0.97%
SPP Solar	6.27	0.68%
SPP Solid Waste	5.33	0.58%
Mini Hydro	30.21	3.28%
Total	921.98	

For Current Year

Category	Dispatch (GWh)	Percentage
CEB Hydro	1,108.9	22.91%
CEB Thermal Oil	747.5	15.44%
CEB Coal	2,025.2	41.84%
IPP Thermal	697.1	14.40%
SPP Wind	49.4	1.02%
CEB Wind	62.7	1.30%
SPP Solar	29.9	0.62%
SPP Solid Waste	23.1	0.48%
Mini Hydro	96.6	2.00%
Total	4,840.1	

CEB owned Thermal Plant Dispatch


April 25, 2022



Available Generation is estimated based on plant availability at 6.00am on

April 26, 2022

CEB owned Thermal Plant Loading at the Night Peak




Note- Plant availability is recorded at 6.00 am on

April 26, 2022

IPP owned Thermal Plant Dispatch

April 25, 2022


V Power Pallekale, Vpower Galle, V Power Horana, Vpower Hambantota, Vpower Valachchena and Altaqa Mahiyanganaya are not available due to expiration of PPAs



Available Generation is estimated based on plant availability at 6.00am on

April 26, 2022

IPP owned Thermal Plant Loading at the Night Peak




Note- Plant availability is recorded at 6.00 am on

April 26, 2022

Major Hydro Plant Dispatch

April 25, 2022




Available Generation is estimated based on plant availability at 6.00am on April 26, 2022
 Broadlands power plant is operating in the Commissioning Stage

April 26, 2022

Major Hydro Plant Loading at Night Peak

April 25, 2022



Note- Plant availability is recorded at 6.00 am on April 26, 2022
 Broadlands power plant is operating in the Commissioning Stage

Summary of Major Plant performance


Plant	Installed Capacity	Plant Availability	Night peak Load	Plant Dispatch
	(MW)	(MW)	(MW)	(MWh)
Wimalasurendra	50	25	10	228
Old Laxapana	54	54	53	614
Canyon	60	60	30	409
New Laxapana	100	100	100	1,352
Polpitiya	90	90	81	987
Broadlands	35	18	17	62
Kotmale	201	134	30	80
Victoria	225	225	101	1,205
Randenigala	114	114	46	707
Rantambe	50	50	0	242
Ukuwela	37	36	0	20
Bowatenna	40	40	0	62
Upper Kotmale	150	150	150	1,015
Nilambe	3	2	0	40
Samanalawewa	120	120	40	149
Kukule	75	75	64	1,386
Inginiyagala	11	5	4	0
Udawalawe	6	2	3	67
Puttalam Coal I	270	270	275	6,569
Puttalam Coal II	270	270	268	6,519
Puttalam Coal III	270	270	271	6,542
KPS Small GTs	64	16	0	0
KPS GT 7	115	115	0	0
KCCP	161	152	125	3,531
Sapugaskanda A	70	49	48	1,096
Sapugaskanda B	70	63	63	1,366
Uthura Janani	26	16	16	481
Barge CEB	60	60	60	1,369
CEB-Thulhiriya	10	6	6	122
CEB-Kolonnawa	20	10	10	189
CEB-Mathugama	20	5	3	83
ACE Matara	24	24	24	401
Asia Power	51	22	27	654
Sojitz Kelanitissa	163	130	129	2,404
West Coast	270	270	0	0
ACE Embilipitiya	93	79	79	1,426
Total	3,448	3,126	2,184	42,959

Plant availability is the availability recorded at 6 am on

April 26, 2022

Contribution to the Night Peak in MW


April 25, 2022



Night Peak*	2,183.9 MW
Day Peak	1,999.9 MW
Minimum Demand	1,347.2 MW


Above figures are excluding contribution from Roof Top Solar, 1MW solar, certain Wind plants and Mini Hydro plants

Reservoir Levels - as at 06.00 Hr on April 26, 2022




Total Reservoir Level	425.5 GWh
% of Total capacity	40.2%

Comparison of Total Reservoir Storage Levels with Past Years




Data for 2018 and 2019 are only available for part of year.

Variation of Major Hydro Reservoir Levels in the current year (GWh)



Variation of Demand during the current year




The above figures are excluding contribution from Roof Top Solar, 1MW solar, certain Wind plants and Mini Hydro plants

Daily Load Curve of the Previous day


April 24, 2022

Solar and wind data is based on Telemetered Power Stations only




Coal Generation during the Previous day

April 24, 2022




CEB Oil Plant Generation during the Previous day

April 24, 2022




IPP Oil Plant Generation during the Previous day

April 24, 2022



Major Hydro Generation during the Previous day


April 24, 2022



Wind Generation during the Previous day

April 24, 2022


Based on Telemetered Power Stations only




Solar Generation during the Previous day

April 24, 2022

Based on Telemetered Power Stations only



Cumulative Dispatch Comparison with Last Year



Thermal Plant Fuel types

Power Station	Primary Fuel
CEB Thermal	
Sapugaskanda 1	Heavy Fuel
Sapugaskanda 2	Heavy Fuel
Kelanitissa Small Gas Turbines	Auto Diesel
GT 7 - Kelanitissa	Auto Diesel
Kelanitissa CCY	Naphtha or Diesel
Lakvijaya 1	Coal
Lakvijaya 2	Coal
Lakvijaya 3	Coal
Uthuru Janani	Heavy Fuel
Barge CEB	Heavy Fuel

Power Station	Primary Fuel
Private Thermal	
Sojitz - Kelanitissa	Auto Diesel
West Coast	Heavy Fuel
ACE Matara	Heavy Fuel
ACE Embilipitiya	Heavy Fuel
Asia Power	Heavy Fuel

Major Incidents during the day -as reported by CEB morning of

April 26, 2022

- 1) Rotational manual load shedding was carried out from 9:00 hrs to 21:20 hrs.