


Generation and Reservoirs Statistics

January 15, 2023



PUBLIC UTILITIES COMMISSION OF SRI LANKA

Daily Generation Mix in MWh



Total Generation (Excluding estimated figures) = 32,850 MWh

Estimated figures of CEB generation report

- Estimated unserved energy = 0 GWh
- Estimated Mini Hydro (Non telemetered) = 1586 MWh
- Estimated IPP Solar PV (Bulk 1-10MW) = 304MWh
- Estimated Solar Roof Top PV = 1480 MWh

Cumulative Dispatch

Following data excludes the contribution from roof top solar, non telemetered solar and mini hydro plants

For Current Month


Category	Dispatch (GWh)	
CEB Hydro	165	31.32%
CEB Coal	196	37.10%
CEB Thermal Oil	77	14.66%
IPP Thermal	43	8.08%
SPP Wind	10	1.92%
CEB Wind	13	2.52%
Mini Hydro (Telemetered)	14	2.65%
IPP Solar(Bulk-10MW)	5	0.88%
IPP Wasteheat + BMP	5	0.87%
Total	527	

For Current Year

Category	Dispatch (GWh)	
CEB Hydro	165	31.32%
CEB Coal	196	37.10%
CEB Thermal Oil	77	14.66%
IPP Thermal	43	8.08%
SPP Wind	10	1.92%
CEB Wind	13	2.52%
Mini Hydro (Telemetered)	14	2.65%
IPP Solar(Bulk-10MW)	5	0.88%
IPP Wasteheat	5	0.87%
Total	527	

CEB owned Thermal Plant Dispatch


January 15, 2023



Available Generation is estimated based on plant availability at 6.00am on

January 16, 2023

CEB owned Thermal Plant Loading at the Night Peak




Note- Plant availability is recorded at 6.00 am on

January 16, 2023

IPP owned Thermal Plant Dispatch

January 15, 2023


Asia Power, V Power Pallekale, Vpower Galle, V Power Horana, Vpower Hambantota, Vpower Valachchena and Altaqa Mahiyanganaya, Sojitz kelanitissa are not available due to expiration of PPAs



Available Generation is estimated based on plant availability at 6.00am on

January 16, 2023

IPP owned Thermal Plant Loading at the Night Peak




Note- Plant availability is recorded at 6.00 am on

January 0, 1900

Major Hydro Plant Dispatch

January 15, 2023




Available Generation is estimated based on plant availability at 6.00am on

January 16, 2023

Broadlands power plant is operating in the Commissioning Stage

Major Hydro Plant Loading at Night Peak

January 15, 2023



Note- Plant availability is recorded at 6.00 am on

January 16, 2023

Broadlands power plant is operating in the Commissioning Stage

Summary of Major Plant performance


Plant	Installed Capacity	Plant Availability	Night peak Load	Plant Dispatch
	(MW)	(MW)	(MW)	(MWh)
Wimalasurendra	50	50	50	270
Old Laxapana	54	52	53	635
Canyon	60	60	41	321
New Laxapana	100	50	50	960
Polpitiya	90	45	46	859
Broadlands	35	0	10	84
Kotmale	201	201	195	800
Victoria	225	234	175	1,945
Randenigala	114	55	59	1,030
Rantambe	50	50	21	526
Ukuwela	37	20	21	502
Bowatenna	40	38	38	92
Upper Kotmale	150	150	80	332
Nilambe	3	3	3	20
Samanalawewa	120	120	101	962
Kukule	75	0	0	0
Inginiyagala	11	7	5	113
Udawalawe	6	3	3	48
Puttalam Coal I	270	0	0	0
Puttalam Coal II	270	270	271	6,459
Puttalam Coal III	270	270	271	6,488
KPS Small GTs	64	32	0	0
KPS GT 7	115	115	0	0
KCCP	161	158	154	3,735
Sapugaskanda A	70	48	50	1,055
Sapugaskanda B	70	63	63	1,496
Uthura Janani	26	16	24	167
Barge CEB	60	60	59	1,384
CEB-Thulhiriya	10	0	0	0
CEB-Kolonnawa	20	0	0	0
CEB-Mathugama	20	13	0	0
ACE Matara	24	0	0	0
Asia Power	50	0	0	0
Sojitz Kelanitissa	163	0	0	0
West Coast	270	270	0	0
Nothern Power	36	0	0	0
ACE Embilipitiya	93	0	0	0
Total	3,483	2,453	1,922	32,854

Plant availability is the availability recorded at 6 am on

January 16, 2023

Contribution to the Night Peak in MW

January 15, 2023




Night Peak*	1,920.8 MW
Day Peak	1,347.8 MW
Minimum Demand	1,102.2 MW

Above figures are excluding contribution from roof top solar, non telemetered solar and mini hydro plants


Reservoir Levels -

as at 06.00 Hr on January 16, 2023




Total Reservoir Level	838.9 GWh
% of Total capacity	69.6%


Comparison of Total Reservoir Storage Levels with Past Years



Variation of Major Hydro Reservoir Levels in the current year (GWh)



Variation of Demand during the current year






The above figures are excluding contribution from roof top solar, non telemetered solar and mini hydro plants



Daily Load Curve of the Previous day

January 14, 2023

Solar and wind data is based on Telemetered Power Stations only








Wind Generation during the Previous day

January 14, 2023


Based on Telemetered Power Stations only




Solar Generation during the Previous day

January 14, 2023

Based on Telemetered Power Stations only



Cumulative Dispatch Comparison with Last Year



Thermal Plant Fuel types

Power Station	Primary Fuel
CEB Thermal	
Sapugaskanda 1	Heavy Fuel
Sapugaskanda 2	Heavy Fuel
Kelanitissa Small Gas Turbines	Auto Diesel
GT 7 - Kelanitissa	Auto Diesel
Kelanitissa CCY	Naphtha or Diesel
Lakvijaya 1	Coal
Lakvijaya 2	Coal
Lakvijaya 3	Coal
Uthuru Janani	Heavy Fuel
Barge CEB	Heavy Fuel

Power Station	Primary Fuel
Private Thermal	
West Coast	Auto Diesel / Heavy Fuel

Major Incidents reported during the day
1) Nil.

January 15, 2023